

Appendix-A

Energy Analysis

B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R																																								
Energy Analysis																																																								
For HP																																																								
Steam Enthalpy MW																																																								
t/h kg/s kJ/kg																																																								
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td colspan="4">HP Turbine calculation</td> </tr> <tr> <td>For HP</td><td>Input Steam</td><td>Output</td><td></td></tr> <tr> <td></td><td></td><td></td><td></td></tr> <tr> <td></td><td>973</td><td>270.278</td><td>3390.6 916.404</td></tr> <tr> <td></td><td></td><td></td><td></td></tr> <tr> <td></td><td>883.6</td><td>245.444</td><td>3059.3 750.888</td></tr> <tr> <td></td><td></td><td></td><td></td></tr> <tr> <td></td><td>85.03</td><td>23.6194</td><td>3059.3 72.259</td></tr> <tr> <td></td><td></td><td></td><td></td></tr> <tr> <td></td><td>4.37</td><td>1.21389</td><td>3059.3 3.71365</td></tr> </table>																	HP Turbine calculation				For HP	Input Steam	Output							973	270.278	3390.6 916.404						883.6	245.444	3059.3 750.888						85.03	23.6194	3059.3 72.259						4.37	1.21389	3059.3 3.71365
HP Turbine calculation																																																								
For HP	Input Steam	Output																																																						
	973	270.278	3390.6 916.404																																																					
	883.6	245.444	3059.3 750.888																																																					
	85.03	23.6194	3059.3 72.259																																																					
	4.37	1.21389	3059.3 3.71365																																																					
Work output 89.543																																																								
Without Solar With Solar																																																								
For IP	m(t/h)	m(kg/s)	h	mxh(MW)									m(t/h)	m(kg/s)	h	mxh(MW)																																								
input	883.6	245.4444	3537.1	868.161544									968.63	269.064	3537.1	951.7058814																																								
output	49.53	13.75833	3362.1	46.2568925									804.513	223.476	2984.9	667.0531875																																								
	43.56	12.1	3165.6	38.30376									54.2963	15.0823	3362.1	50.70825462																																								
	54.53	15.14722	2984.9	45.2129436									47.7518	13.2644	3165.6	41.98978163																																								
	733.89	203.8583	2984.9	608.496739									59.7775	16.6049	2984.9	49.56384514																																								
	2.09	0.580556	2984.9	1.73290028									2.09	0.58056	2984.9	1.732900278																																								
	Work output				128.158309									Work output	140.6579122																																									
Power boosting when steam is not extracted from HP Turbine = 12.4996 MW																																																								
With Solar																																																								
For LP	m(t/h)	m(kg/s)	h	mxh(MW)									m(t/h)	m(kg/s)	h	mxh(MW)																																								
Input	733.89	203.8583	2984.9	608.496739									804.513	223.476	2984.9	667.0531875																																								
Output	660.95	183.5972	2382.2	437.365303									724.554	201.265	2382.2	479.453546																																								
	27.53	7.647222	2639.8	20.1871372									30.1792	8.38312	2639.8	22.12977221																																								
	23.12	6.422222	2746.9	17.6412022									25.3449	7.04024	2746.9	19.33883851																																								
													25.1147	6.97629	2515	17.54538031																																								

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	
			733.89	203.8583	2984.9	608.496739						59.7775	16.6049	2984.9	49.56384514		
			2.09	0.580556	2984.9	1.73290028						2.09	0.58056	2984.9	1.732900278		
			Work output				128.158309							Work output	140.6579122		
Power boosting when steam is not extracted from HP Turbine = 12.4996 MW																	
With Solar																	
For LP	m(t/h)	m(kg/s)	h	mxh(MW)									m(t/h)	m(kg/s)	h	mxh(MW)	
Input	733.89	203.8583	2984.9	608.496739									804.513	223.476	2984.9	667.0531875	
Output	660.95	183.5972	2382.2	437.365303									724.554	201.265	2382.2	479.453546	
	27.53	7.647222	2639.8	20.1871372									30.1792	8.38312	2639.8	22.12977221	
	23.12	6.422222	2746.9	17.6412022									25.3449	7.04024	2746.9	19.33883851	
			22.91	6.363889	2515	16.0051806							25.1147	6.97629	2515	17.54538031	
			Work output				117.297916							Work output	128.5856505		
Power boosting when steam is not extracted from HP Turbine = 11.2877 MW																	
Total output of coal plant = 334.9993 335 MW																	
Now	Total increase in ouput of solar coal hybrid power plant = 23.7873 MW																
	Therefore, total ouput of the hybrid plant = 358.787337 MW																
	therefore, to produce 335 MW power with solar energy steam required will be = 908.491 t/h																
	therefore, for generating 908.913 t/h steam the coal required will be = 140.055 t/h																
	Coal Saving 9.94489 t/h																

Exergy Analysis

% Exergy Analysis

$$W_{net} = 309.875;$$

$$Q_s = 72.26;$$

$$dP = 24;$$

$$\begin{aligned} eb &= (21.7672 + 340.05187*C - 831.916575*H + 477.8328*O + 5.25*N + 2237.1669*S - \\ &48.81534*as)/1000; \end{aligned}$$

$$ex_eff = W_{net}/(41.67*eb);$$

$$ex_in = (1 - ((4*298)/(3*5777)) * (1 - 0.28 * \log(1.35 * 10^{-5}))) * Q_s;$$

$$Ex_Pi = dP/ex_in;$$

$$AA = [ex_eff, \quad Ex_Pi]$$

Economic Analysis

% Given data

$$d = 0.12; \%$$

$$n = 25; \text{ % Life of power plant} = 25 \text{ Years}$$

$$PCF = 0.85; \text{ % Plant capacity factor} = 0.85$$

$$APC = 0.075; \text{ % Auxiliary power consumption} = 7.5\%$$

$$FC = 0.03252; \text{ % Fuel Cost USD per kg}$$

FOM = 27.66; % USD/kWe

UHRnet = 7388.89; %

NCV = 15907; % cccccccc or 15907 kJ/kg

Cvom = 0.003252; % Variable O&M per unit USD/kWh

e = 0.02; % Ref Suresh et al. (2%)

TCC = 794.17*10^6; % Total Capital Cost in USD

PG = 670000; % Generator Output = 670*1000;

CC = TCC/PG; % The capital cost per unit (CC)

CRF = (d*(1+d)^n)/((1+d)^n-1); % Capital Recovery Factor

ACC = CC*CRF; % Annualised capital cost per kW

Pnet = 365*24*PCF*(1-APC); % Net annual energy generated

FCC = ACC/Pnet; % Fixed capital cost per unit

Cfom = FOM/Pnet; % Fixed O&M cost per unit

Cf = FC*UHRnet/NCV; % Fuel cost per unit

Cv = Cf + Cvom; % Total variable cost per unit

ACoE = FCC + Cfom + Cv; % Annualized cost of electricity generation

de = (d-e)/(1+e); % Equivalent discount rate with escalation

LF = (((1+de)^n)-1)/((de*(1+de)^n))*(((d*(1+d)^n)/((1+d)^n-1)); % Levellizing Factor

Cl = LF*(Cfom+Cv); % Levelised fuel & O&M cost

LCoE = FCC+Cl; % Levelised cost of electricity generation

SPP = (CC)/(ACoE*Pnet); % Simple payback period

AA=[TCC, PG, CC, CRF, ACC, Pnet, FCC, Cfom, Cf, Cv, ACoE, de, LF, Cl, LCoE, SPP]